

**CERTIFICATE OF COMPLIANCE
OF PRODUCTION CONTROL ON-SITE**

CE N° 0380 - CPR - 111

In the framework of the EU Regulation N° 305/2011 set forth by the European Parliament and the Council on 09 March, 2011, which harmonised the conditions to commercialise construction products and repealed Directive 89/106/CEE of the Council, it was established that for the following product:

ROLPIN PYRO

Thickness : 7 to 21 mm / Density : 500 to 680 kg/m³

Classification: B-s2,d0 according to EN 13501-1

(european classification report n° ctba 06/RC 02),

(Terms of use of the product: see attached annex)

Produced by: NP ROLPIN

**Manufactured in the facility located in:
1964 rue de la Grande Lande - - 40210 LABOUHEYRE**

FCBA, as the notified body N° 0380, determined the typical product on the basis of typical tests (including sampling), calculations concerning the type, values from tables or documentation describing the product; carried out the initial inspection of the fabrication facility and tested production on site, as well as carrying out surveillance, assessment and continuous approval of the on-site production (system 1).

The present certificate attests that all provisions concerning the conformity attestation of the on-site production set forth in the harmonised technical specification of reference **NF EN 13986: 2004 + A1 : 2015** have been applied.

This certificate was issued for the first time on **18/07/2013**, and except for withdrawal or suspension, shall remain valid as long as the conditions described in the harmonised technical specifications, production conditions on the site and production testing in the facility shall continue to conform.

The list of valid certificates of conformity can be accessed on the www.fcba.fr site.

(In case of litigation, only the French version of the present certificate is the authentic text).

ANNEX

CE Performance constancy Certificate

N° 111/2014-GB/4 du 27/04/2017

CLASSIFICATION IS VALID IN TERMS OF USE FOLLOWING PRODUCT

« ROLPIN PYRO »:

Valid with or without air gap. Screwed mounting on a wood or steel on a substrat A2.

For the tichness < 10mm, this application is valid without air gap on a substrat A2 or better.